
PERIODIC INSPECTION REPORT

Date: **September 10, 2026**

File: **3722626**

An inspection of the project noted below was conducted on August 21, 2026. A copy of this report has been forwarded to the owner. Should you have any questions or concerns regarding this report, please do not hesitate to call us.

PROJECT: R.M. of Big Arm Municipal Shop

Permit Number:

Project address: **54 Prince St**

Municipality: **Town of Imperial**

Legal Description:

Inspection Number: **1**

Construction Status (stage of construction):

Foundation and framing complete.

Comments (weather, site conditions, noteworthy matters, person(s) contacted):

Clear, 24° C. No one available on site for inspection.

Notes/Observations (Point form descriptions of items reviewed and comments):

- Foundation appears to be pile and grade beam system.
- Framing is completed and not visible for inspection.
- Interior metal cladding installed on walls and ceiling.
- Exterior metal cladding installed, metal soffit and fascia complete.
- Attic accesses installed as per plans.
- Doors swing with exit travel.
- No utilities installed at time of inspection.

Action taken (It is the owners responsibility to comply with this report):

The following are required to be completed.

- 1) **The owner holds a duty to ensure the professional engineer inspects the construction on site to ensure that the construction conforms to the design and the code.**
- 2) **Submit mechanical and electrical designs for review. This must be submitted immediately.**
- 3) Emergency lighting must be installed to illuminate exits and principal routes providing access to exits in an open floor area.
- 4) Portable fire extinguishers must be placed throughout the floor area in conformance with NFPA 10.
- 5) Ensure the 6 mil CGSB poly, 2" rigid insulation and 6" compacted granular base are installed below the slab.

Inspection Date: **August 21, 2026**

Building Official: _____



Amanda Kaufmann

Report Sent to: **Town of Imperial** ☒ Yes ☐ No

cc: R.M. of Big Arm 251 (email: rm251@sasktel.net)